



NOTE 3

NOTE:
 1. ALL EXTERIOR PIPEWORK 25mm OR LESS TO BE INSULATED.
 2. HOSE CONNECTION IS 2" MINSUP CLAW COUPLING.
 3. PENSTOCK VALVES TO BE LOCKABLE.

FOR CONSTRUCTION

No.	Revision	By	Chk	Appd	Date
2	ISSUED FOR CONSTRUCTION	J.C.	ATG	DAP	5.02.07
1	ISSUED FOR CONSTRUCTION	J.C.	ATG	DAP	10.11.06
0	ISSUE FOR TENDER	SK	ATG	AWW	22.09.06

Drawing Originator:
BECC Engineers = Planners = Managers

Original Scale (A1)	Design	AGT	JULY 06	Approved For Construction*
NT5	Drawn	SK	JULY 06	
Reduced Scale (A3)	Dwg Verifier	ADT	NOV 06	
	Dwg Check	SBS	NOV 06	Date

* Refer to Revision 1 for Original Signature

Client: **Coliban WATER**

Project: **EPSOM SPRING GULLY RECYCLED WATER**

Title: **LOW LIFT PUMP STATION PROCESS AND INSTRUMENTATION DIAGRAM**

Discipline	Process
Drawing No.	3552306-100-PR001
Rev.	2

Document No. 3552306-100-PR001.DWG