



NOTE:  
 1. PROVIDE 1 No. BLANK FLANGE FOR SECONDARY ISOLATION OF HIGH PRESSURE LINE WHEN A PUMP IS REMOVED FOR SERVICE.  
 2. VALVE TO BE LOCKED.

PROVISION OF AIR RELEASE VALVE OR VACUUM PUMP FACILITY IF REQUIRED REFER S.D./LEIGHTON

**FOR CONSTRUCTION**

No.	Revision	By	Chk	Appd	Date
2	ISSUED FOR CONSTRUCTION	J.C.	ATG	DAP	5.02.07
1	ISSUED FOR CONSTRUCTION	J.C.	ATG	DAP	10.11.06
0	ISSUE FOR TENDER	SBS	ATG	AWW	22.09.06

Drawing Originator:  
**Engineers ■ Planners ■ Managers**

Original Scale (A1)	Design	AGT	JULY 06	Approved For Construction*
NTS	Drawn	SK	JULY 06	
Reduced Scale (A3)	Dwg Verifier	ADT	NOV 06	
	Dwg Check	SBS	NOV 06	Date

\* Refer to Revision 1 for Original Signature

Client: **Coliban WATER**

Project: **EPSOM SPRING GULLY RECYCLED WATER**

Title: **HIGH LIFT PUMP STATION PROCESS AND INSTRUMENTATION DIAGRAM**

Discipline	PROCESS
Drawing No.	3552306-300-PR002
Rev.	2